

# Emission Test Certificate

Thursday December 13<sup>th</sup>, 2012

Supplier: Ozone Panel Pty Ltd (Level 31, 367 Collins St, Melbourne, VIC, 3000)

Sample Description: Ozone Panel

Date Tested: November 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: GREENGUARD Certification Program for Low Emitting Products incorporating ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<b>GREENGUARD Certification Program Emission Criteria for Ceiling Systems</b>	<b>Ozone Panel</b>
Formaldehyde $\leq 0.06 \text{ mg/m}^3$	0.096 $\text{mg/m}^3$
Total Aldehydes $\leq 0.043 \text{ ppm}$	0.319 ppm
Total Volatile Organic Compounds $\leq 0.5 \text{ mg/m}^3$	0.106 $\text{mg/m}^3$ Individual VOCs were all less than one quarter of their Threshold Limit Value. Carcinogens and reproductive toxins were not identified as part of the VOCs.



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

Project CV121032